



**South Ripley**  
SOLAR PROJECT

**ConnectGen Chautauqua County LLC**  
South Ripley Solar Project  
Matter No. 21-00750

**900-2.8 Exhibit 7**

**Supplement**

**Noise and Vibration**

## TABLE OF CONTENTS

EXHIBIT 7	NOISE AND VIBRATION .....	1
(a)	Noise Impacts Study .....	1
(b)	Design Goals .....	1
(c)	Radius of Evaluation .....	2
(d)	Modeling standards, input parameters, and assumptions .....	2
(e)	Evaluation of Prominent Tones for Design .....	4
(f)	Evaluation of Low Frequency Noise for Wind Facilities .....	5
(g)	Evaluation of Infrasound for Wind Facilities .....	5
(h)	Map of Study Area .....	5
(i)	Ambient pre-construction baseline noise conditions .....	5
(j)	Construction Noise .....	7
(k)	Sound Levels in Graphical Format .....	11
(l)	Maximum sound impacts .....	11
(m)	Potential community noise impacts .....	13
(1)	Potential for Hearing Damage .....	13
(2)	Potential for Structural Damage .....	13
(n)	Noise Abatement Measures for Facility Construction .....	13
(o)	Noise Abatement Measures for Facility Design and Operation .....	14
(p)	Software Input Parameters .....	15
(q)	Miscellaneous .....	15
REFERENCES	.....	16

## LIST OF TABLES

Table 7-1. Facility Design Goals .....	2
Table 7-2. Modeling Standards .....	4
Table 7-3. Cumulative Construction Noise at Sensitive Receptors .....	10
Table 7-4. Modeled Sound Level Results .....	12
Table 7-5. Modeled Sound Level Results Compared with Design Goals .....	12
Table 7-6. Maximum Modeled Octave Band Sound Level Results at a Sensitive Receptor .....	12

## LIST OF FIGURES

- Figure 7-1. Sound Contours and Sensitive Receptors  
 Figure 7-2. Sound Contours for Substation Sound

## LIST OF APPENDICES

- Appendix 7-A. Project Noise Impact Assessment  
 Appendix 7-B. Draft Complaint Management Plan

## EXHIBIT 7 NOISE AND VIBRATION

### (a) Noise Impacts Study

Exhibit 7 contains a detailed analysis of the potential sound impacts associated with the construction and operation of the Project. Potential sources of sound from the Facility include the step-up transformer in the collection substation, electrical inverters and transformers within the various solar panel fields, HVAC equipment and inverters associated with the energy storage facilities and operations buildings, and temporary construction-related noise. As described in the Project Noise Impact Assessment (PNIA) (Appendix 7-A), this equipment generates sound, but sound generated by the Project meets all 94-c noise limits intended to protect neighboring residences, wildlife, and other sensitive receptors. There are no vibration issues associated with the operation of such a facility and vibration during construction is expected to be minimal. The sound modeling has been updated to reflect the new location of the proposed POI facility and substation configuration on the same parcel originally proposed.

The PNIA was prepared by Resource Systems Group, Inc. (RSG), a member of the National Council of Acoustical Consultants, under the direction of Kenneth Kaliski. Mr. Kaliski is Board Certified through the Institute of Noise Control Engineering and has 35 years of experience at RSG. He previously testified as an expert on Article 10 noise issues in such cases as Cassadaga Wind and Baron Winds.

### (b) Design Goals

Noise standards applicable to the Facility Site are described below and in Table 7-1. More information on these standards is included in Section 2 of the PNIA. Compliance with these standards is discussed below and in Table 7-2. The Facility has been designed to comply with all relevant design goals outlined in Table 7-1. There were no quantifiable local noise limits in the existing zoning law for the Town of Ripley at the time of the Application. The Town of Ripley has subsequently adopted an amendment to the zoning law with a provision updating the noise requirements for solar facilities, as follows:

*“J. Noise: Once in operation, sound pressure level at the exterior of any residence or nonparticipating property line, expressed in terms of dBA Leq-8hr, shall not exceed existing background ambient noise, expressed in dBA Leq-8hr as measured by a qualified acoustician, by more than 6 dB “(Town of Ripley Planning Board, May 2021).*

This amendment does not provide ascertainable noise limits and the Applicant is requesting that this provision of the Zoning Law be waived (if it is deemed applicable) as is discussed in more detail in Exhibit 24. The Facility has been designed to adhere to ORES required noise levels as described in Table 7.1.

**Table 7-1. Facility Design Goals**

<b>Standard</b>	<b>Location</b>	<b>Maximum Sound Level</b>
900-2.7(b)(2)(i)	Outside of any existing non-participating residence	45 dBA L <sub>8h</sub>
900-2.7(b)(2)(i)	Outside of any existing participating residence	55 dBA L <sub>8h</sub>
900-2.7(b)(2)(ii)	Outside of any existing non-participating residence from the collector substation	40 dBA L <sub>1h</sub>
900-2.7(b)(2)(iii)	Outside of any existing non-participating residence	5 dB penalty to the above limits for producing any audible prominent tones
900-2.7(b)(2)(iv)	Short-term equivalent continuous average sound level from the facility across any portion of a non-participating property	55 dBA L <sub>8h</sub>

**(c) Radius of Evaluation**

Evaluation of the maximum noise levels to be produced during operation of the Facility was conducted within the Sound Study Area which extends at a minimum, 1,500 feet from the edge of the Facility components or until the 30-dBA noise contour is reached, whichever is greater. Figure 7-1 identifies noise contours and all sensitive sound receptors and boundary lines (differentiating participating and non-participating parcels) and noise sources within the Sound Study Area including transformer(s), inverters, and other noise sources, if any).

A cumulative analysis requires modeling to include noise from any solar facility and substation existing and proposed by the time of filing the application and any existing sensitive receptors within a 3,000-foot radius from any noise source proposed for this Facility or within the 30 dBA noise contour, whichever is greater. There are no other solar facilities within 3,000 feet of a Project noise source or within the 30 dBA noise contour and the existing South Ripley Substation does not include a high voltage transformer nor is it currently functional (it is current operating as a transmission pass through), so a cumulative analysis is not required.

**(d) Modeling standards, input parameters, and assumptions**

The analysis performed to model the sound levels produced by the Project utilized the following parameters as required in Section 900-2.8(d) of the 94-c regulations. Future Project sound levels during construction and operation of the Facility were modeled in accordance with the standard ISO 9613-2, “Acoustics – Attenuation of sound during propagation outdoors, Part 2: General Method of Calculation” for full octave bands from 31.5 Hz to 8000 Hz utilizing the Cadna/A acoustical modeling software from DataKustik GmbH. ISO 9613-2 assumes downwind sound propagation between every source and every receptor, consequently, all wind directions, including the prevailing wind directions,

are taken into account. For solar facilities, the ISO 9613-2 model is more likely to overestimate sound levels. First, the barrier-effect of the solar panels in blocking sound from interior sources, especially inverters and medium-voltage transformers, was not taken into account in the modeling done for this Project. Second, sound emissions of solar equipment tend to be highest during sunny days. Under these conditions, the sound is refracted upwards, lowering the sound levels measured near the ground. Under the modeling assumptions used in this report, the meteorological conditions are always downward refracting, such as occurs during cloudy days with moderate downwind conditions or a well-developed moderate nighttime temperature inversion. No meteorological correction ( $C_{met}$ ) was used. Additional model assumptions include the following:

- All noise sources operating simultaneously and at maximum sound power;
- The ground absorption factor was set to  $G=0.5$  (half hard/half porous), except within the Battery Energy Storage System (BESS) facility fence line where the ground absorption factor was set to  $G=0$  (hard ground);
- Atmospheric attenuation calculated using a temperature of 10°C and 70 percent relative humidity;
- A receptor height of 1.5 meters above ground; and
- No additional uncertainty adjustment added to or subtracted from the modeling results.

Noise standards applicable to the Facility Site, as well as noise guidelines that are required, or recommended, by various agencies, are described below. More information on these standards is included in Section 2 of the PNIA. Compliance with these standards is discussed below and in Table 7-2.

#### *Local Regulations*

At the time of Application filing, the Town of Ripley regulated solar projects under its Solar Energy Law in Section 620 of the Zoning Ordinance which did not identify any quantitative noise limits. Subsequent to Application filing, the Town adopted a new Solar Energy Zoning Law which addresses noise as follows:

*“J. Noise: Once in operation, sound pressure level at the exterior of any residence or nonparticipating property line, expressed in terms of dBA Leq-8hr, shall not exceed existing background ambient noise, expressed in dBA Leq-8hr as measured by a qualified acoustician, by more than 6dB “(Town of Ripley Planning Board, May 2021).*

Please see Exhibit 24 for a comprehensive discussion of town requirements, quantitative noise limits, and waiver requests.

### State Regulations

The State of New York regulates noise from this Project under 94-c. The 94-c noise limits are shown in Table 7-1.

### Federal Standards and Guidelines

No federal noise standards apply to solar power production or energy storage on private land.

Noise standards applicable to the Facility, are provided below in Table 7-2. The Facility has been designed to meet the existing Town and 94-c noise limits. As indicated in Table 7-2, the Facility is modeled as being in compliance with all of the standards applicable to the Facility.

**Table 7-2. Modeling Standards**

Standard	Maximum Sound Level	Number of exceedances
900-2.7(b)(2)(i)	45 dBA L <sub>8h</sub> at non-participating residence	0 (0%)
900-2.7(b)(2)(i)	55 dBA L <sub>8h</sub> at participating residence	0 (0%)
900-2.7(b)(2)(ii)	40 dBA L <sub>1h</sub> from substation transformer	0 (0%)
900-2.7(b)(2)(iii)	5 dB penalty to the above limits for producing any audible prominent tones	All sources assumed tonal. With penalty applied 0 (0% of) homes exceed above limits
900-2.7(b)(2)(iv)	55 dBA L <sub>8h</sub> at non-participating property lines	0 (0%)

The maximum modeled A-weighted overall sound levels for each sensitive sound receptor and most impacted property lines are found in Appendix C of the PNIA and presented in a spreadsheet compatible format. The maximum Z-weighted octave band sound levels, from 31.5 Hz to 8,000 Hz, are found in Appendix D of the PNIA. The number of receptors exposed to sound levels greater than 35 dBA are found in Table 8 of the PNIA. Sound contour maps are found in Figure 7-1 for the entire Facility Site and in Figure 7-2 for the collection substation only. Within the PNIA, these maps are Figures 28 to 34 (in 1:12000 scale).

### (e) Evaluation of Prominent Tones for Design

Section 900-2.8 (b)(2)(iii) of the 94-c regulations requires an assumption of tonality for all sources for which 1/3 octave band data from the manufacturer is not available. In this case, this information is not available for any source. As

such, all sources are assumed to be tonal and prominent according to ANSI/ASA S12.9-2005/Part 4 Annex C at the source and receiver. As such, a 5 dB penalty is applied to all sources after modeling.

**(f) Evaluation of Low Frequency Noise for Wind Facilities**

The proposed Facility is not a wind facility and therefore the requirements of §900-2.7(f) are not applicable.

**(g) Evaluation of Infrasound for Wind Facilities**

The proposed Facility is not a wind facility and therefore the requirements of §900-2.7(g) are not applicable.

**(h) Map of Study Area**

A map of the Sound Study Area showing the location of sensitive sound receptors and boundary lines (differentiating participating [i.e., a contract has been signed with the Applicant prior to the date of Application filing], potentially participating, and non-participating parcels) within 1,500 feet of the proposed Facility components is provided in Figure 7-1 and 7-2. The figure also depicts all potential noise sources within the Sound Study Area, including transformer(s), inverters, the substation, and the energy storage structures. The sensitive sound receptors include all residences, outdoor public facilities and areas, hospitals, schools, libraries, parks, camps, summer camps, places of worship, cemeteries, Federal, State, and local Lands, and cabins and hunting camps identified by property tax codes that were identified within 1,500 feet of the Facility. Seasonal receptors included any other seasonal residences with septic systems/running water. All residences are included as sensitive sound receptors, regardless of participation in the project or occupancy (i.e., year-round and seasonal residences are included). A references list of all receptors and corresponding Tax ID numbers can be found in Table 22 of the revised PNIA.

**(i) Ambient pre-construction baseline noise conditions**

Pre-construction baseline noise conditions were evaluated using the  $L_{90}$  statistical and the  $L_{eq}$  energy-based noise descriptors, and by following the recommendations included in ANSI/ASA S3/SC1.100-2014-ANSI/ASA S12.100-2014 American National Standard entitled Methods to Define and Measure the Residual Sound in Protected Natural and Quiet Residential Areas. Sound level monitoring was performed for a total of approximately 15 days.

*Ambient Sound Monitoring Locations*

On behalf of the Applicant, RSG completed winter (leaf-off) and summer (leaf-on) background sound level monitoring at six representative locations distributed throughout the Facility Site. The monitoring locations were selected to be as representative as possible of the broader local soundscapes that exist in the immediate region. The various representative areas included rural residential, low and high traffic roads, and remote areas. Table 2 of the PNIA

indicates the site characteristics of each monitoring location. Additional detail on each monitoring location is described in Section 5 of the PNIA.

#### *Ambient Sound Level Monitoring*

Background sound level monitoring was performed at these six locations during the winter of 2020 (March 4 to 12) and the summer of 2020 (July 9 to 16). Sound level data were collected using one to four Cesva SC310s, two to three Svantek 979, and zero to two Cirrus CR-171 Class 1 sound level meters, depending on the season, that continuously logged 1/3-octave band sound levels logged once each second. The microphones were fixed to temporary posts at a height of 1.2 meters (approximately 4 feet) above local grade. Each instrument was field calibrated before and after monitoring periods, with either a Cesva CB-5, Larson Davis CAL200, or Brüel Kjær 4231 calibrator. Additional detail is provided in Section 4 of the PNIA.

Statistical sound level data were averaged into 10-minute increments and summarized over the monitoring period. Statistical levels were calculated from the one-second equivalent continuous sound levels ( $L_{1-sec}$ ). The 1/3 octave band spectra were also recorded at each location to document any pre-existing tonal sounds. Biogenic sounds, including insects, amphibians, and birds were excluded through the application of the “ANS” frequency-weighting network. If tones above 1.25 kilohertz (kHz) were detected, then the A-weighted sound level was recalculated by summing 1/3 octave bands from 20 Hz to 1.25 kHz, effectively removing the high-frequency portion of the sound. Additional detail on the background sound level monitoring methodology and data analysis is provided in Section 4.4 of the PNIA.

#### *Baseline Sound Monitoring Results*

Equivalent continuous sound levels,  $L_{eq}$ , are the energy-average level over a period of time. The 10<sup>th</sup> percentile sound levels ( $L_{90}$ ) are the statistical value above which 90% of the sound levels occurred during an interval.

The sound levels for the winter and summer monitoring periods for all six sites are summarized in Tables 4 to 6 of the PNIA. Except for the substation location, the nighttime  $L_{eq}$ s are less than the daytime levels, which is typical and indicates a diurnal pattern. The difference between the overall  $L_{eq}$  and overall  $L_{90}$  for each site ranged from 10 dB to 19 dB. A larger difference between the  $L_{eq}$  and  $L_{90}$  indicates that the soundscape is more likely to include transient or intermittent sounds, such as aircraft overflights or passing automobiles and farm equipment. Graphical timelines for the A-weighted  $L_{eq}$  and  $L_{90}$  broadband noise levels for both summer and winter monitoring at each monitoring location are found in Section 5 of the PNIA.



## (j) Construction Noise

In contrast to other forms of power generation, the duration of the construction phase for a PV solar facility is short and the activities that generate significant noise are few. Where a fossil fuel or wind generating project would require the pouring of concrete foundations and the delivery and assembly of very large components, construction of a solar facility largely involves the installation of mounting posts for the PV panel racking, manual installation of the individual panels, some grading and earthwork, erection of the collection substation and energy storage facility, and collection line trenching. The duration of the construction phase for the Facility is anticipated to require approximately 19 months, although the activities that generate any significant sound are few and not anticipated to exceed the full phase of construction. Construction of the Facility is proposed to take place from 7:00 AM to 6:00 PM Monday through Saturday. While some activities may take place on occasional Sundays, pile driving will be restricted to Monday through Saturday.

Noise resulting from construction was modeled with ISO 9613-2, *Acoustics – Attenuation of Sound During Propagation Outdoors, Part 2: General Method of Calculation* (ISO 9613-2) 3-D sound propagation standard as implemented in the Cadna/A software package. Sound source information was obtained from the Federal Highway Administration's (FHWA) Roadway Construction Noise Model and manufacturer data. For construction noise modeling, construction activities were categorized into eight groups: road construction, substation and energy storage construction, trenching, array inverter construction, piling, racking, boring, and laydown yards. The closest receptors were identified to each phase and the worst-case areas around the Facility Site were modeled assuming the maximum sound emissions of all associated construction equipment operating simultaneously.

All operational modeling standards, input parameters, and assumptions followed those outlined in (d) above. The results of the construction noise modeling are summarized below and are provided in additional detail in Section 7 of the PNIA. 1:12,000 maps of the maximum construction phase are shown in Appendix G of the PNIA.

- Facility road construction would take place within and adjacent to the solar arrays. The primary noise sources associated with this activity are excavators, dozers, graders, dump trucks, and rollers. The cumulative maximum modeled sound results of all primary road construction sources operating simultaneously near the closest receptor (Receptor ID 38) is 80 dBA. See Figure 37 and Table 10 of the PNIA.
- The primary sources of noise associated with the construction of the substation and energy storage facility are excavators, dozers, graders, dump trucks, rollers, concrete mixing trucks, concrete pumper trucks, flatbed trucks, man-lifts, and large and small cranes. The cumulative maximum modeled sound results of all primary substation and energy storage construction sources operating simultaneously near the closest receptor (Receptor ID 6) is 76 dBA. See Figure 38 and Table 11 of the PNIA.

- Trenching would take place along the underground collection line routes throughout the Facility Site. The primary noise sources associated with this activity are excavators, dozers, rollers, compactors, flatbed trucks, forklifts, and trenchers. The cumulative maximum modeled sound results of all primary trenching sources operating simultaneously near the closest receptor (Receptor ID 38) is 83 dBA. See Figure 39 and Table 12 of the PNIA.
- Array inverter and transformer construction would take place at pads throughout the solar arrays. The primary noise sources associated with this activity are excavators, dozers, graders, rollers, dump trucks, concrete mixing trucks, and concrete pumping trucks. The cumulative maximum modeled sound results of all primary construction sources operating simultaneously during this phase near the closest receptor (Receptor ID 23) is 71 dBA. See Figure 40 and Table 13 of the PNIA.
- Piling would take place throughout the solar arrays. The primary noise sources associated with this activity are flatbed trucks, boom trucks, and pile drivers. The cumulative maximum modeled sound results of all primary piling sources operating simultaneously near the closest receptor (Receptor ID 86) is 70 dBA. See Figure 41 and Table 14 of the PNIA.
- Racking would take place throughout the solar arrays. The primary noise sources associated with this activity are flatbed trucks and forklifts. The cumulative maximum modeled sound results of all primary racking sources operating simultaneously near the closest receptor (Receptor ID106) is 76 dBA. See Figure 42 and Table 15 of the PNIA.
- Boring would take place along portions of the underground collection line routes throughout the Project area and would primarily involve the use of a boring machine. Boring typically only lasts one to three days in any given location, so the potential impacts are relatively short-lived. The maximum modeled sound results of boring near the closest receptor (Receptor ID 27) is approximately 72 dBA. See Figure 43 and Table 16 of the PNIA
- Equipment staging would take place at all laydown yards across the Facility Site. Assuming all laydown yards operated at their maximum sound emissions, the cumulative maximum sound level would be 77 dBA at the closest home, Receptor 93. See Figure 44 and Table 17 of the PNIA.

Additionally, to further quantify the potential cumulative impact of construction noise across the Facility Site in conformance with 900-2.8(j)(2), the construction sound for each of the eight groups described above was run simultaneously for each discrete construction area based on the potential for the greatest amount of cumulative impact due to concurrent stages of construction. Under the construction schedule, there may be one week when all categories

of construction activity could occur at the same time. Based on the construction schedule required for the proposed commercial operation date, the greatest potential for concurrent construction noise would occur during the overlap of site preparation, pile driving, and initial racking activities. All operational modeling standards, input parameters, and assumptions followed those outlined in (d) above. The following assumptions were utilized to model cumulative construction impact:

- Road construction (as described above) would occur along the full length of each proposed access road concurrently across the Facility Site;
- Construction of the substation and energy storage facility (as described above) would occur concurrently for all stages of its construction at once;
- Trenching (as described above) would take place along the full length of all underground collection line routes throughout the Facility Site concurrently;
- Array inverter and transformer construction (as described above) would take place at all proposed pads throughout the solar arrays concurrently for all stages of inverter construction at once;
- Piling (as described above) would take place throughout the solar arrays concurrently. Given the potential for multiple pile drivers operating at the same time is possible within larger arrays of construction, but unlikely in smaller arrays, the Applicant prepared a schedule of locations based on array size to model the concurrent pile driving. Piling driving sound was modeled at all of the 78 identified locations (typically located at the center point of a construction array) concurrently with the rest of the construction sound on this list;
- While racking would take place throughout the solar arrays once piling driving and other site preparations are completed, it is unlikely that material amounts of racking would be underway concurrently with all of the other construction activities within this list. Therefore, the Applicant prepared a subset of locations (22 in total) which reflect construction areas large enough for concurrent scheduling of pile driving and racking. Racking sound was modeled at those locations concurrently with the rest of the construction sound on this list;
- Boring (as described above) would take place at all bore pits located throughout the Project area concurrently;
- Equipment staging (as described above) would take place at all laydown yards across the Facility Site concurrently.

See Table 18 and Appendix G in the PNIA for more information on the cumulative impact modeling. The results for the ten receptors with the largest potential for impact were as follows. A complete list of cumulative noise at each receptor can be found in Table 25 of the PNIA.

**Table 7-3. Cumulative Construction Noise at Sensitive Receptors**

Receptor	Participating/Non-Participating	Cumulative Noise Measurement
103	Participating <sup>1</sup>	90
25	Participating	86
20	Participating	86
35	Participating	85
23	Non-Participating	85
36	Participating	85
93	Non-Participating	84
45	Participating	84
44	Participating	84
47	Non-Participating	83

While this analysis captures a hypothetical maximum potential noise impact of the cumulative impact of all phases of concurrent construction, it inherently overpredicts the potential for noise generation. Specifically, this analysis assumes that all phases of concurrent construction would occur simultaneously at all possible locations across the Facility Site with each piece of equipment at their maximum sound levels. While useful for modeling maximum impact, it is not typical, nor possible, for all sites across a Facility of this size to be under construction at a single time. For example:

- In the case of access roads, there will be no situation in which all 39 access roads would be under construction at a single time. Typically, a project will have a small number of construction teams constructing access roads in sequence, with only a handful under construction at a single time.
- In the case of pile driving, while it is possible that multiple separate arrays would be undergoing pile driving at a single time, and some with more than one pile driver (depending on array size) operating concurrently, a project of this size would have no more than 10 to 15 pile drivers across the whole site at a single time. Under the assumptions described above, while the pile driver locations modeled do provide an effective estimate of the potential for multiple pile drivers operating concurrently in a discrete area near a specific

<sup>1</sup> Receptor is hunting cabin that is planned to be removed by landowner prior to Facility construction.

sensitive receptor, by modelling 78 pile drivers operating concurrently across the Facility Site, the model overestimates the total potential for noise generation.

- In the case of inverter pad construction, there will be no situation in which all 137 inverter/transformer pads would be under construction at a single time. Typically, a project will have a small number of construction teams constructing pad locations in sequence, with only a handful under construction at a single time.
- In the case of underground collection construction, the trenching and boring equipment was modeled as happening simultaneously along the full length of each underground collection line and at each bore location across the Facility Site. This overestimates the potential noise generation because trenching construction crews will only be working at a single discrete point along a collection line at a single time as they move along. Additionally, it is not typical for all collection line across a full Facility Site to be constructed at a single time, rather only a handful under construction at a single time.

Therefore, while the cumulative analysis helps to quantify the maximum potential impact of cumulative construction activities at each sensitive receptor, the actual level of noise generation during construction will be significantly lower across the whole site, and each sensitive receptor will also likely experience far less impact, more consistent with a staged construction schedule with less concurrent activities and wider spread between work areas.

#### **(k) Sound Levels in Graphical Format**

As described above, Figures 7-1 and 7-2 depict sound contours, all sensitive sound receptors and boundary lines, and all noise sources from the Facility at a scale of 1:12,000. Sound contours are rendered at least until the 30 dBA noise contour is reached, in 1 dBA steps with sound contour multiples of 5 dBA differentiated. Similarly scaled maps are also shown in the PNIA in Figures 29 to 36 for operations and Appendix G for construction. Full-size hard copy maps (22" x 34") will be submitted to ORES.

#### **(l) Maximum sound impacts**

The sound propagation modeling done in the PNIA assumes the sun is always shining during the daylight hours and that the sunlight is always strong enough to generate the maximum power of the Facility, at the same time the energy storage units are continuously fully charging or discharging over an eight-hour period. These are conservative assumptions not representative of actual project operating conditions. However, for the purposes of this modeling exercise it represents a worst-case evaluation. Sound levels from the Project will likely be lower for most of the time,

as the sun is not always shining, the HVAC on the energy storage is not always running at 100% output, meteorological conditions are not always favorable for propagation<sup>2</sup>, and the solar panels will act, to some extent, as sound barriers.

The A-weighted sound levels at the sensitive sound receptors, for the operating Facility are provided in Table 7-3 below as a tabular comparison between maximum sound impacts and state requirements (standards) for the Facility (see Table 7-2).

**Table 7-4. Modeled Sound Level Results**

	Minimum	Maximum	Average
Non-participating residence	25 dBA	45 dBA	36 dBA
Participating residence	n/a	53 dBA	n/a
From substation transformer	n/a	40 dBA	n/a
Tonal penalty applied to the above	+5 dB	+5 dB	+5 dB
Non-participating property line	n/a	53 dBA	n/a

The maximum sound impacts, compared with the Project design goals, are shown in Table 7-4, below.

**Table 7-5. Modeled Sound Level Results Compared with Design Goals**

	Maximum	Plus 5 dB Tonal Penalty	Standard	Standard met?
Non-participating residence	40 dBA	45 dBA	45 dBA	Yes
Participating residence	48 dBA	53 dBA	55 dBA	Yes
From substation transformer	35 dBA	40 dBA	40 dBA	Yes
Non-participating property line	53 dBA	n/a	55 dBA	Yes

The maximum sound levels at 1/1 octave bands are shown in Table 7-5, below.

**Table 7-6. Maximum Modeled Octave Band Sound Level Results at a Sensitive Receptor**

1/1 Octave Band Sound Pressure Level (dBZ), Maximum L <sub>8h</sub>								
31.5 Hz	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
51	46	48	39	37	35	34	31	18

<sup>2</sup> Sound propagates relatively poorly on sunny days relative to cloudy days or nighttime conditions.

**(m) Potential community noise impacts**

**(1) Potential for Hearing Damage**

The Facility's potential to result in hearing damage was evaluated against three guidelines established by the Occupational Safety and Health Administration (OSHA) and World Health Organization (WHO). Comparison of sound propagation modeling to these guidelines shows that construction and operation of the Facility will not result in potential for hearing damage. Each of these standards, and the Facility's compliance with them, is further described below.

OSHA protects against the effects of noise exposure in the workplace. Permissible noise exposure levels for an eight-hour day are 90 dBA. At sound levels above 85 dBA over an eight-hour workday, employers shall provide hearing protection to employees. Sound pressure levels, as generated by Facility construction and operation at sensitive sound receptors, will be under this threshold, so the Facility will be in compliance with OSHA standards. Therefore, based on the OSHA standard, the Facility will not result in potential for hearing damage.

The WHO long-term guideline to protect against hearing impairment is 70 dBA  $L_{eq-24h}$  over a lifetime exposure, and 120- and 140-dB peak sound levels for impulsive sounds (e.g., blasting) for children and adults, respectively. No blasting will be required for the construction of the Facility, and construction noise levels at the closest receptors were modeled well below the 120- and 140-dB thresholds. In addition, the operation of the Facility will not produce noise levels over 70 dBA  $L_{eq-24h}$ . Therefore, there is no potential for hearing impairment from construction or operation of the Facility.

**(2) Potential for Structural Damage**

As previously indicated, at this time, blasting activities are not anticipated during construction of the Facility. It is also not anticipated that any other construction activities (such as excavation, pile driving, boring, or rock hammering) will produce any cracks, settlements, or structural damage to existing proximal buildings or infrastructure, including any residences or historic buildings.

**(n) Noise Abatement Measures for Facility Construction**

A Draft Complaint Management Plan has been prepared for the Facility in accordance with pre-construction compliance filings under 19 NYCRR 900-10.2(e)(7). Please see Appendix 7-B. The Draft Complaint Management Plan will detail the process for receiving and resolving any complaints received during construction and operation of the Facility, including any noise and vibration complaints. A Final Complaint Management Plan will be filed as a pre-construction compliance filing under 19 NYCRR 900-10.2(e)(7).

The Applicant takes seriously any reasonable complaints that it receives from members of the public. The Draft Plan details instructions for registering complaints, including via phone, writing, or email. The Applicant will also implement a comprehensive complaint response procedure and timeline, which may include community engagement, gathering information, investigation, response to the complaint, a follow up after the response has been issued, and further action if the complainant believes that the issue continues to exist.

Although impacts related to construction noise will be temporary, and are not anticipated to be significant, measures employed to minimize and mitigate temporary construction noise may include:

- Utilizing construction equipment fitted with proper functioning exhaust systems and mufflers,
- Locating all stationary noise-generating equipment, such as air compressors and portable power generators, a minimum of 200 feet from adjacent residential structures,
- Maintaining equipment and surface irregularities on construction sites to prevent unnecessary noise,
- To the extent feasible, configuring the construction in a manner that keeps loud equipment and activities as far as possible from noise-sensitive locations,
- Developing a staging plan that establishes equipment and material staging areas at least 200 feet away from sensitive receptors when feasible,
- Requiring contractors to use approved haul routes to minimize noise at residential and other sensitive noise receptor sites, and
- Prohibiting unnecessary idling of internal combustion engines.

**(o) Noise Abatement Measures for Facility Design and Operation**

Adverse noise impacts will be avoided or minimized through careful siting of Facility components, the use of alternative designs, and alternative technologies. Noise abatement measures proposed for the Facility are generally centered around the energy storage facility and include the use of low-noise condenser fans on the air handling units.

Two noise abatement measures have been incorporated into the Facility design to minimize the potential sound impact of the collection substation and high voltage main power transformer. First, the main power transformer will be specified with a maximum sound level equal to the NEMA-TR-1 standard minus 10 dB. Second, the Facility will include two noise barriers constructed around a portion of the substation fence line and adjacent to the main power transformer. The larger, exterior barrier is approximately 390 feet in length and 20 feet in height and is located along the northern and western sides of the collection substation fence line. The smaller barrier is approximately 35 feet in length and 12 feet in height and is located directly adjacent to and on the northern side of the main power transformer. The walls will



consist of concrete posts or steel beams supporting pre-cast panels with a neutral color and stone texture (or similar). These noise barriers are shown graphically in Figure 28 of the PNIA and in Appendix 5-D.

**(p) Software Input Parameters**

Specific modeling parameters are included as Appendix B of the PNIA prepared by RSG. GIS files containing modeled topography, noise source and sensitive sound receptor locations, and all external boundary lines identified by Parcel ID number are being provided to ORES under separate cover in digital format. Similarly, the Cadna/A computer noise modeling files are being provided to ORES in digital format. Substation site plan and elevation details are provided in Appendix 5-D.

The locations of all noise sources are identified in Figures 7-1 and 7-2 and GIS coordinates are provided to ORES under separate cover in digital format. Sound information from the manufacturers for all noise sources included in this analysis are presented in Appendices B and H of the PNIA (Appendix 7-A)

**(q) Miscellaneous**

- 1) A glossary of terminology, definitions, abbreviation, and references is included in Appendix F of the PNIA.
- 2) As previously noted, sound monitoring information will be provided to ORES in a spreadsheet compatible format under separate cover and will be presented in accordance with the requirements outlined in Section 900-2.8(q)(2). The number of sensitive receptors exceeding design goals is shown in Table 16 of the PNIA. No sensitive sound receptors are modeled to be exposed to Project sound levels that exceed design goals or noise limits. The number of receptors at sound levels above 35 dBA, in 1 dB bins, is shown in Table 18 of the PNIA.

## REFERENCES

International Organization for Standardization (ISO). 1989. *ISO 9613-2 Acoustics – Attenuation of Sound During Propagation Outdoors*, Part 2, “A General Method of Calculations.” ISO 9613-2, Geneva, Switzerland, 1989.

The Town of Ripley Planning Board. 2021. Local Law No. 1 of 2021. Available at: <https://www.ripleyny.org/>

United States Department of Transportation (USDOT), Federal Highway Administration. 2006. *Roadway Construction Noise Model User’s Guide*. Table 1. January 2006.

United States Environmental Protection Agency (USEPA). 1974. *Information on Levels of Environmental Noise Requisite to Protect Public Health and Welfare with an Adequate Margin of Safety*. 550/9-74-004, March 1974.

World Health Organization (WHO). 1999. *Guidelines for Community Noise*.

WHO. 2009. *Night Noise Guidelines for Europe*.